

# WATER WELL REPORT

STATE OF WASHINGTON

Application No.

Permit No.

(1) OWNER: Name Bill Erickson Address P.O. Box 1029 Stanwood Wa. 98292  
(2) LOCATION OF WELL: County Island SE 1/4 Sec 5 T30 N. R3 W.M.  
Bearing and distance from section or subdivision corner Cont. Lot 4

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐  
Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) \_\_\_\_\_  
New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 209 ft. Depth of completed well 209 ft.

## (6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 204 ft.  
Threaded ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Welded ☒ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒

Type of perforator used \_\_\_\_\_  
SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name JOHNSON  
Type 1 Model No. \_\_\_\_\_  
Diam. 5 Slot size #10 from 205 ft. to 209 ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name \_\_\_\_\_

Type: \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS:

Land-surface elevation above mean sea level \_\_\_\_\_ ft.

Static level 176 ft. below top of well Date 6-11-84

Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☒ No ☐ If yes, by whom? D.P. Drilling

Yield: 35 gal/min. with 9.8 ft. drawdown after 1 hrs.

" 35 " 10 " 2 "

" 10.5 " 4 "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
------	-------------	------	-------------	------	-------------

2 Min.	175'3"	3 Min.	177'	4 Min.	178'8"
--------	--------	--------	------	--------	--------

Date of test \_\_\_\_\_

AIR Bailor test 15 gal/min. with 35 ft. drawdown after \_\_\_\_\_ hrs.

Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_

Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☒ No ☐

## (10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sand - Gravel	0	70
Sand	70	190
Blue Clay	190	201
Sand - Water	201	209

DEC 19 1984

Work started 6-7- 19 84 Completed 6-11- 19 84

## WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME DAHLMAN PUMP & DRILLING INC.  
(Person, firm, or corporation) (Type or print)

Address P.O. BOX 422 Burlington Wa. 98233

[Signed] H. Ken Fowler  
(Well Driller)

License No 1192

Date 6-12- 19 84